

## Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. RDWS/26-27/830  
FSD

Date: 25/5/2026

It is certified that an inspection team headed by Punith Kumar H , Senior Analyst from R.D.W & S D inspected the Shree Channamallikarjuna School, Shikaripura on 25/5/2026 and on the basis of water test report No. SMG/25MAY/0128 dated 23/5/2026 of District water quality Testing Laboratory, RDWSD,Shivamogga Certified that Shree Channmallikarjuna School has safe drinking water facilities for the students and members of staff of the institution. The School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 25/5/2027

Signature with Seal: .....

  
R.D.W.S & S. D  
Division, Shimoga

RDW&SD,Shivamogga

To  
Shree Channamallikarjuna  
School(CBSE),  
Channakeshavanagara,Shikaripura



**RURAL DRINKING WATER & SANITATION DEPARTMENT**  
Shivamogga District Level Water Quality Testing Laboratory  
DC Compound, RTO Office Road, Shivamogga-577201

TEST REPORT					
<b>Address :</b> M/S. Shree Channamallikarjuna School (CBSE), Channakeshavanagara, Shikaripura Shivamogga				Report date: 23.05.2026	
				Reference: TRF	
				Sample receipt date: 20.05.2026	
				Sample code: SMG26MAY0128	
				Date of Sample collection: 20.05.2026	
				Analysis start date: 21.05.2026	
				Analysis completion date: 22.05.2026	
Sample Particulars: Water from Purification Plant				Sample collection Method: CUSTOMER	
				Sample quantity: 1 litre	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Test Method
Description: Clear Sample					
1	pH Value @25°C	7.15	6.5 – 8.5	No relaxation	IS 3025 (Part-11) :2022
2	Specific Conductance, µS/cm@25°C	188	-	-	IS 3025 (Part-14) :2019
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Taste	Agreeable	Agreeable	Agreeable	IS3025(Part-8):2023
5	Colour, Hazen Units	<5	5	15	IS 3025 (Part-4) :2021
6	Turbidity, NTU	0.2	1	5	IS 3025 (Part-10) : 1984
7	Total Dissolved Solids @ 105°C, mg/l	122	500	2000	IS 3025 (Part-16) : 2023
8	Alkalinity as CaCO <sub>3</sub> , mg/l	46.8	200	600	IS 3025 (Part-23) : 1986
9	Total Hardness as CaCO <sub>3</sub> , mg/l	36.0	200	600	IS 3025 (Part-21) : 2009
10	Calcium as Ca, mg/l	9.6	75	200	IS 3025 (Part-40) : 1991
11	Magnesium as Mg, mg/l	2.8	30	100	IS 3025 (Part-46) : 2022
12	Chloride as Cl, mg/l	26.6	250	1000	IS 3025 (Part-32) : 1988
13	Sulphate as SO <sub>4</sub> , mg/l	4.8	200	400	IS 3025 (Part-24) : 2022
14	Fluoride as F, mg/l	0.06	1	1.5	APHA 23 <sup>rd</sup> Edition
15	Nitrate as NO <sub>3</sub> , mg/l	2.4	45	No relaxation	APHA 23 <sup>rd</sup> Edition
16	Iron as Fe, mg/l	0.08	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: The above analyzed sample confirms to the Acceptable limits of IS 10500:2018 Drinking Water Specification for the above tested parameters only.					
Analysed by: Junior Analyst (Sunil Kumar N S)			Authorized Signatory: Technical Manager (Punith Kuamr H)		

.....END OF THE REPORT.....

**Note:**

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

Analyst  
RDWSD/WQMSP/DR/01  
Division, Shivmogs